

ORDINANCE NO. 24-___

**AMENDMENT TO ZONING ORDINANCE REGARDING
BATTERY ENERGY STORAGE SYSTEMS**

Saline Township, Washtenaw County, Michigan

An ordinance to amend the Saline Township Zoning Ordinance to add regulations for Battery Energy Storage Systems.

The Township Board of Saline Township, Washtenaw County, Michigan ordains:

Section 1. Amended to Article 18.

Article 18 Definition is amended to add the following definitions.

ARTICLE 18 – DEFINITIONS

191. **Essential Services.** The erection, construction, alteration or maintenance, by public utilities or municipal departments, of underground, surface or overhead gas, electrical, steam, fuel or water transmission or distribution systems or collection, communication, supply or disposal systems therewith that are reasonably necessary for the furnishing of adequate service for the general health, safety and welfare.
- a. Poles, wires, mains, drains, sewers, pipes, conduits, transformers, splice boxes, cables, towers, fire alarm boxes, police call boxes, traffic signals, hydrants or similar equipment and accessories associated with an essential service shall be considered essential services under this Ordinance.
 - b. Wireless communication facilities, wind energy conversion systems (WECS), private community wastewater treatment and disposal systems (PCWS), battery energy storage systems (BESS), and utility buildings and storage yards shall not be considered essential services under this Ordinance.
192. **Utility, Private.** A person, firm, corporation or private entity duly authorized to furnish and furnishing, under federal, state or municipal regulations or franchise agreements, to the public: gas, steam, electricity, communication, telegraph or transportation. Such uses as wind energy conversion systems (WECS), community wells, private community wastewater treatment and disposal systems (PCWS), radio stations, battery energy storage systems (BESS), and wireless communication facilities shall be considered private utilities under this Ordinance.
193. **Utility, Public.** A governmental entity or municipal department, board or commission duly authorized to furnish and furnishing, under federal, state, or municipal regulations, electricity, gas, steam, communications, telegraph, or transportation to

the public. Such utility shall be regulated by a governmental pricing structure, have the right of eminent domain, be a single entity as designated by Federal or State government to provide a specified service or product, and provide a service considered essential to a public need.

- a. Publicly owned and operated or municipal water distribution and sanitary sewer systems, and stormwater drainage facilities under the jurisdiction of the Washtenaw County Drain Commissioner, shall also be considered public utilities.
- b. Such uses as wind energy conversion systems (WECS), community wells, private community wastewater treatment and disposal systems (PCWS), radio stations, battery energy storage systems (BESS), and wireless communication facilities shall not be considered public utilities under this Ordinance.

Section 2. Amendment to Section 12.01.B.

Section 12.01.B. is amended in its entirety to read as follows:

Section 12.01 Site Plan Review

B. Site Plan Approval Required.

Two separate review processes have been established in accordance with the purpose of this Section, as follows:

1. **Planning Commission approval.** The following development projects and uses shall require review and approval of a detailed final site plan by the Planning Commission prior to establishment, construction, expansion or structural alteration of any structure or use. Exceptions listed below shall not be subject to plan review, but shall be subject to zoning permit approval per Section 1.07 (Zoning Permits):
 - a. All special approval uses, subject to the provisions of Section 12.02 (Special Uses).
 - b. All RURAL USES, as specified in Article 4 (Land Use Table), except farming and active agricultural uses and designated rural accessory uses.
 - c. All RESIDENTIAL USES, as specified in Article 4 (Land Use Table), except the following:
 - (i) One (1) single-family, two-family or duplex dwelling and customary accessory structures on a single residential lot

of record.

- (ii) Family and group day care homes, and adult foster care family homes, as licensed by the State of Michigan.
 - (iii) Establishment of a home occupation listed in Section 5.204 (Home Occupations) as a permitted accessory use.
- d. All OFFICE, SERVICE, AND COMMUNITY USES, COMMERCIAL USES, AND INDUSTRIAL, RESEARCH, AND LABORATORY USES, as specified in Article 4 (Land Use Table).
 - e. All OTHER USES, as specified in Article 4 (Land Use Table), except accessory structures and uses specified in Section 6.101 (Accessory Structures and Uses), temporary construction buildings and uses, Tier 1 Battery Energy Storage Systems (BESS), and essential service and public utility facilities.
 - f. Construction, expansion or alteration of a manufactured housing park, as defined in Section 18.02 (Definitions), shall be subject to preliminary plan approval in accordance with the procedures and standards of Section
 - g. 5.205 (Manufactured Housing Parks).
 - h. Construction, expansion or alteration of a condominium development, as defined in Section 18.02 (Definitions), shall be subject to condominium site plan approval in accordance with the procedures and standards of Article 13 (Condominium Regulations).
 - i. Construction, expansion or alteration of a planned unit development (PUD) project shall be subject to development plan approval in accordance with the procedures and standards of Article 14 (Planned Unit Developments).
 - j. Construction, expansion or alteration of a wireless communications facility, as defined in Section 18.02 (Definitions), shall be subject to approval in accordance with the procedures and standards of Section 11.02 (Wireless Communication Facilities).

Section 3. Amendment to Section 4.02

Section 4.02 is amended in its entirety to read as follows:

Section 4.02 Table of Permitted Uses by District

SYMBOL	KEY		DISTRICTS													
	P	Permitted Uses												Principal Use		
	S	in the Zoning												Special Use		
	A	District												Accessory Use		
[Blank]	Prohibited Use in the Zoning						R-4									
USES																
Adult Entertainment Uses and Sexually-Oriented Businesses												S				Section 5.601
Aircraft Landing Strips	S													P		Section 5.602
Composting Centers	S												S	S		Section 5.603
Extractive Operations, Sand and Gravel Pits	S															Section 5.604
Private Off-Road Courses	S															Section 5.605
Public Works or Road Maintenance Yards													S	P		Section 5.504
Racetracks														S		Section 5.606
Recycling Collection Facility													P	P		Section 5.504
Temporary Structures for Construction Purposes	P	P	P	P	P	A	P	P	P	P	P	P	P	P		
Topsoil Removal or Stockpiling on Sites Under Development	S	A	A	A	A	A	A	A	A	A	A	A	A	A		Section 5.607
Tier 2 Battery Energy Storage Systems (BESS)	S												S	S		Section 11.10

Section 4. Amendment to Article 11.

Article 11 is amended to add the Section 11.10

ARTICLE 11 SPECIAL DEVELOPMENT PROVISIONS

Section 11.10 Battery Energy Storage Systems

A. Intent.

It is the intent of Saline Township to regulate the siting, design, installation, and operation of Battery Energy Storage Systems (BESS). These standards permit the efficient and effective operation of BESS within the Township while mitigating their potential negative impacts and ensuring their compatibility with adjacent land uses in order to protect public health, safety, and welfare. Battery energy storage systems, as defined herein, are only permitted as authorized by this Section.

B. Definitions.

As used in this Section the following terms shall have the meanings indicated:

ANSI: American National Standards Institute

BATTERY(IES): A single cell or a group of cells connected together electrically in series, in parallel, or a combination of both, which can charge, discharge, and store energy electrochemically. For the purposes of this law, batteries utilized in consumer products are excluded from these requirements.

BATTERY ENERGY STORAGE MANAGEMENT SYSTEM: An electronic system that protects energy storage systems from operating outside their safe operating parameters and disconnects electrical power to the energy storage system or places it in a safe condition if potentially hazardous temperatures or other conditions are detected.

BATTERY ENERGY STORAGE SYSTEM (BESS): One or more devices, assembled together, capable of storing energy in order to supply electrical energy at a future time, not to include a stand-alone 12-volt car battery or an electric motor vehicle. A battery energy storage system (BESS) is classified as a Tier 1 or Tier 2 Battery Energy Storage System as follows:

1. Tier 1 Battery Energy Storage Systems have an aggregate energy capacity less than or equal to 600kWh and, if in a room or enclosed area, consist of only a single energy storage system technology.
2. Tier 2 Battery Energy Storage Systems have an aggregate energy capacity

greater than 600kWh or are comprised of more than one storage battery technology in a room or enclosed area.

BUILDING CODE: Stille-DeRossett-Hale Single State Construction Code Act (Act No. 230, P.A. 1972, as amended)

CELL: The basic electrochemical unit, characterized by an anode and a cathode, used to receive, store, and deliver electrical energy.

COMMISSIONING: A systematic process that provides documented confirmation that a battery energy storage system functions according to the intended design criteria and complies with applicable code requirements.

DEDICATED-USE BUILDING: A building that is built for the primary intention of housing battery energy storage system equipment, is classified as Group F-1 occupancy as defined in the Building Code, and complies with the following:

1. The building's only use is battery energy storage, energy generation, and other electrical grid-related operations.
2. No other occupancy types are permitted in the building.
3. Occupants in the rooms and areas containing battery energy storage systems are limited to personnel that operate, maintain, service, test, and repair the battery energy storage system and other energy systems.
4. Administrative and support personnel are permitted in areas within the buildings that do not contain battery energy storage system, provided the following:
 - a. The areas do not occupy more than 10 percent of the building area of the story in which they are located.
 - b. A means of egress is provided from the administrative and support use areas to the public way that does not require occupants to traverse through areas containing battery energy storage systems or other energy system equipment.

FIRE CODE: 2021 Edition of the International Fire Code, the Appendix chapters, including the reference standards" as published by the International Code Council, as adopted by the Township of Saline in the State of Michigan.

NATIONALLY RECOGNIZED TESTING LABORATORY (NRTL): A U.S. Department of Labor designation recognizing a private sector organization to perform certification for certain products to ensure that they meet the requirements of both the construction and general industry OSHA electrical standards.

NEC: National Electric Code.

NFPA: National Fire Protection Association.

OUTDOOR INSTALLATIONS: Outdoor installations are battery energy storage systems that are not Dedicated Use-Buildings.

C. Applicability

1. The requirements of this Section shall apply to all battery energy storage systems (BESS) permitted, installed, or modified in Saline Township after the effective date of this Section, excluding general maintenance and repair.
2. Modifications to, retrofits or replacements of an existing battery energy storage system that increase the total battery energy storage system designed discharge duration or power rating shall be subject to this Section.

D. General Requirements

1. **System Certification** System Certification. Battery energy storage systems and equipment shall be listed by a Nationally Recognized Testing Laboratory to UL 9540 (Standard for battery energy storage systems and Equipment) or approved equivalent, with subcomponents meeting each of the following standards as applicable:
 - a. UL 1973 (Standard for Batteries for Use in Stationary, Vehicle Auxiliary Power and Light Electric Rail Applications),
 - b. UL 1642 (Standard for Lithium Batteries),
 - c. UL 1741 or UL 62109 (Inverters and Power Converters),
 - d. Certified under the applicable electrical, building, and fire prevention codes as required.
 - e. Alternatively, field evaluation by an approved testing laboratory for compliance with UL 9540 (or approved equivalent) and applicable codes, regulations and safety standards may be used to meet system certification requirements.
2. **Battery Maintenance.** Battery energy storage systems shall be maintained in good working order and in accordance with industry standards.
3. **Site Maintenance.** Site access shall be maintained, including snow removal

at a level acceptable to the Township and the Saline Area Fire Department.

4. **Visual Impact.** The Battery Energy Storage System shall not have a significant adverse impact on the natural features or neighborhood character of the surrounding area and shall be located to maximize its distance and visibility from adjacent properties and roadways.
5. **Noise.** The 1-hour average noise generated from the battery energy storage systems, components, and associated ancillary equipment shall not exceed a noise level of 45 dBA as measured at any property line where the system is located. Applicants may submit equipment and component manufacturers noise ratings to demonstrate compliance. The Zoning Inspector or Planning Commission may require an applicant to provide an acoustic assessment or sound study prepared by a licensed engineer from a reasonable number of sampled locations at the perimeter of the battery energy storage system to demonstrate compliance with this standard.
6. **Code Compliance.** All Battery Energy Storage Systems, all Dedicated Use Buildings, and all other buildings or structures that (1) contain or are otherwise associated with a Battery energy storage system and (2) subject to the Building Code shall be designed, erected, and installed in accordance with all applicable provisions of the Building Code, all applicable state and federal regulations, and industry standards as referenced in the Building Code and the Saline Township Zoning Ordinance.
7. **Compliance with Additional Codes.** Battery Energy Storage Systems, and the installation and use thereof, shall comply with the Building Code, Fire Code, and other applicable Township, County, and State codes. Installation of a Battery Energy Storage Systems shall not commence until all necessary permits have been obtained.

E. Tier 1 Battery Energy Storage Systems

Tier-1 Battery Energy Storage Systems shall be permitted as an accessory use/structure in all zoning districts, subject to the following standards:

1. **Application for Certificate of Zoning Compliance.** A property owner shall obtain a certificate of zoning compliance prior to constructing a Tier 1 Batter Energy Storage System, unless otherwise exempted by this Ordinance. Applications shall include the following information:
 - a. Photographs of the property's existing conditions.
 - b. Product specifications of the proposed Battery Energy Storage System.

- c. Plot/sketch plan to indicate where the battery energy storage system is to be installed on the property (or, if building-mounted, the system's location on a permanent building), including its setbacks from the property lines.
 - d. Elevations of the battery energy storage system, including the associated building wall or support structure if building mounted.
- 2. **Exemptions from Certificate of Zoning Compliance for Tier 1 Battery Energy Storage Systems.** The following situations do not require a certificate of zoning compliance, but shall still comply with all other standards of this Section:
 - a. Repair and replacement of existing Tier 1 Battery Energy Storage Systems, provided that there is no expansion of the size or capacity of the existing system. This Section does not exempt applicants from obtaining building permits as applicable.
- 3. **Standards for Tier 1 Battery Storage Systems**
 - a. Where feasible, Tier 1 Battery Storage Systems shall be located inside of a building. All Tier 1 Battery Storage Systems that are located outside of a building shall be screened to the maximum extent possible without posing a fire risk. All Tier 1 Battery Storage Systems must be placed in a secure container or enclosure meeting the requirements of the Building Code and, when no longer in use, shall be disposed of in accordance with applicable laws and regulations.
 - b. **Installation and Maintenance.** Tier 1 Battery Energy Storage Systems shall be installed, maintained, and used only in accordance with the manufacturer's directions. A copy of such directions shall be submitted with the application for the certificate of zoning compliance.
 - c. **Setbacks.** In all zoning districts, ground-mounted Battery Energy Storage Systems shall be located only in the rear or side yard and shall conform to the setback requirements of Article 3 (Dimensional Standards).
 - d. **Height.** Ground-mounted Battery Energy Storage Systems shall not exceed sixteen (16) feet in height, measured from the ground at the base of the system to its highest point.
 - e. **Ground-Mounted Systems.** Battery Energy Storage Systems shall

be permanently and safely attached to the ground. Proof of the safety and reliability of the means of attachment shall be submitted to the Zoning Inspector prior to installation. The Township Zoning Inspector may require an additional certification by a professional engineer or other qualified person prior to installation.

- f. **Building-Mounted Systems.** Building-mounted Tier 1 Battery Energy Storage Systems shall only be installed if they can be safely supported by the structure. Proof of the safety and reliability of the means of attachment shall be submitted to the Zoning Inspector prior to installation. The Township Zoning Inspector may require an additional certification by a professional engineer or other qualified person prior to installation.

F. Tier 2 Battery Energy Storage Systems

Tier 2 Battery Energy Storage Systems may be permitted as a special use subject to the following standards.

1. Prior to the construction of a Tier 2 Battery Energy Storage System, an application for a special use permit must be filed and approved according to the procedures established in Section 12.02.
2. The construction and operation of all Tier 2 Battery Energy Storage Systems shall comply with all applicable local, state and federal requirements.
3. No Tier 2 Battery Energy Storage System shall be constructed, installed, or modified as provided in this section without first obtaining all applicable permits.
4. Applications to build a Tier 2 Battery Energy Storage System in Saline Township must be accompanied by the fees required for a special use permit and site plan review.
5. Tier 2 Battery Energy Storage Systems shall not be approved until evidence has been provided to the Planning Commission that the property owners and applicable utility authorities have authorized the proposed system.
6. Application Requirements
7. Applications for the installation, replacement or renewal, or commissioning of a Tier 2 Battery Energy Storage system shall be accompanied by the following information, in addition to all of the

information required for special uses and site plans. The Planning Commission shall have the authority to modify any of the following requirements based on information provided by applicants or recommendations of the Township Engineer, Saline Area Fire Department, or staff. All of the following documents must be prepared by an engineer licensed by the State of Michigan.

- a. **Construction documents.** Construction documents shall include the following plans, manuals, and specifications:
 - (i) Location and layout diagram of the room or area in which the BESS is to be installed.
 - (ii) Details on the hourly fire-resistance ratings of assemblies enclosing the ESS.
 - (iii) The quantities and types of BESS to be installed.
 - (iv) Manufacturer's specifications, ratings and listings of each ESS.
 - (v) Description of energy (battery) management systems and their operation.
 - (vi) Location and content of required signage.
 - (vii) Details on fire suppression, smoke or fire detection, thermal management, ventilation, exhaust and deflagration venting systems, if provided.
 - (viii) Support arrangement associated with the installation, including any required seismic restraint.
 - (ix) **Commissioning Plan.** Such plan shall document and verify that the system and its associated controls and safety systems are in proper working condition per requirements set forth in the Fire Code, Building Code, or applicable standard.
 - (x) **Decommission plan.** A narrative description of the activities to be accomplished, including who will perform that activity and at what point in time, for complete physical removal of all battery energy storage system components, structures, equipment, security barriers, and transmission lines from the site;

- (a) Disposal of all solid and hazardous waste in accordance with local, state, and federal waste disposal regulations;
 - (b) The anticipated life of the battery energy storage system;
 - (c) The estimated decommissioning costs and how said estimate was determined;
 - (d) The method of ensuring that funds will be available for decommissioning and restoration;
 - (e) The method by which the decommissioning cost will be kept current;
 - (f) The manner in which the site will be restored, including a description of how any changes to the surrounding areas and other systems adjacent to the battery energy storage system, such as, but not limited to, structural elements, building penetrations, means of egress, and required fire detection suppression systems, will be protected during decommissioning and confirmed as being acceptable after the system is removed; and
 - (g) A listing of any contingencies for removing an intact operational energy storage system from service, and for removing an energy storage system from service that has been damaged by a fire or other event.
- b. **Hazard Mitigation Analysis.** An analysis that evaluates the consequences of BESS failure modes according to the procedures established in the Fire Code or other applicable standards as determined by the Saline Area Fire Department or Township Engineer.
 - c. **Sound Study.** An acoustic assessment prepared by a licensed engineer from a reasonable number of sampled locations at the perimeter of the battery energy storage system to demonstrate compliance with Section 11.10.D.
 - d. **Fire Safety Compliance Plan.** Such plan shall document and verify that the system and its associated controls and safety systems

are in compliance with the Fire Code.

- e. **Operation and Maintenance Manual.** Such plan shall describe continuing battery energy storage system maintenance and property upkeep, as well as design, construction, installation, testing and commissioning information and shall meet all requirements set forth in the Fire Code and Building Code.
- f. **Emergency Operations Plan.** A copy of the approved Emergency Operations Plan shall be given to the system owner, the local fire department, and local fire code official. A permanent copy shall also be placed in an approved location to be accessible to facility personnel, fire code officials, and emergency responders. The emergency operations plan shall include the following information:
 - (i) Procedures for safe shutdown, de-energizing, or isolation of equipment and systems under emergency conditions to reduce the risk of fire, electric shock, and personal injuries, and for safe start-up following cessation of emergency conditions.
 - (ii) Procedures for inspection and testing of associated alarms, interlocks, and controls.
 - (iii) Procedures to be followed in response to notifications from the Battery Energy Storage Management System, when provided, that could signify potentially dangerous conditions, including shutting down equipment, summoning service and repair personnel, and providing agreed upon notification to fire department personnel for potentially hazardous conditions in the event of a system failure.
 - (iv) Emergency procedures to be followed in case of fire, explosion, release of liquids or vapors, damage to critical moving parts, or other potentially dangerous conditions. Procedures can include sounding the alarm, notifying the fire department, evacuating personnel, de-energizing equipment, and controlling and extinguishing the fire.
 - (v) Response considerations similar to a safety data sheet (SDS) that will address response safety concerns and extinguishment when an SDS is not required.
 - (vi) Procedures for dealing with battery energy storage system

equipment damaged in a fire or other emergency event, including maintaining contact information for personnel qualified to safely remove damaged battery energy storage system equipment from the facility.

- (vii) Other procedures as determined necessary by Saline Township to provide for the safety of occupants, neighboring properties, and emergency responders.
- (viii) Procedures and schedules for conducting drills of these procedures and for training local first responders on the contents of the plan and appropriate response procedures.

8. **Decommissioning Fund.** The applicant for a Tier 2 Battery Energy Storage System shall provide a form of surety, either through an escrow account or bond, to cover the cost of removal in the event Saline Township must remove the installation; the amount of surety shall be determined by the Planning Commission, but shall not exceed more than 125 percent of the cost of removal. The applicant shall submit a fully-inclusive estimate of the costs associated with removal, prepared by a qualified engineer. The amount shall include a mechanism for calculating increased removal costs associated with inflation.

G. Standards for Tier 2 Battery Energy Storage Systems

1. **Setbacks.** Tier 2 Battery Energy Storage Systems shall be set back at least 600 hundred feet from road right-of-way lines and all property lines.
2. **Height.** Tier 2 Battery Energy Storage enclosures shall comply with the building height limitations for principal structures of the underlying zoning district.
3. **Lighting.** Lighting of the battery energy storage systems shall be limited to that minimally required for safety and operational purposes and shall be reasonably shielded and downcast from abutting properties.
4. **Signs.**
 - a. Tier 2 Battery Energy Storage Facilities shall post signs in compliance with ANSI Z535 and shall include the type of technology associated with the battery energy storage systems, any special hazards associated, the type of suppression system installed in the area of battery energy storage systems, and 24-hour emergency contact information, including reach-back phone number. As required by the NEC, disconnect and other

emergency shutoff information shall be clearly displayed on a light reflective surface. A clearly visible warning sign concerning voltage shall be placed at the base of all pad-mounted transformers and substations.

- b. Additional signs may be permitted subject to the requirements of Article 9 of the Zoning Ordinance.
5. **Fencing Requirements.** Tier 2 Battery Energy Storage Systems, including all mechanical equipment, shall be enclosed by a fence with a self-locking gate to prevent unauthorized access unless housed in a dedicated-use building and not interfering with ventilation or exhaust ports.
6. **Containment.** Tier 2 Battery Energy Storage Systems shall include containment systems to prevent chemicals, fire suppressant agents, or similar hazards from contaminating surface water, groundwater, and soil, and to minimize the risk of human exposure.
7. **Vegetation and tree-cutting.** Areas within 20 feet on each side of Tier 2 Battery Energy Storage Systems shall be cleared of combustible vegetation and other combustible growth. Single specimens of trees, shrubbery, or cultivated ground cover such as green grass, ivy, succulents, or similar plants used as ground covers shall be permitted to be exempt provided that they do not form a means of readily transmitting fire. Removal of trees should be minimized to the extent possible.
8. **Screening and Noise Barriers.** Tier 2 Battery Energy Storage Systems shall use architectural features, earth berms, landscaping, or other screening methods that will visually screen the BESS from adjacent properties and function as a sound barrier. These elements shall be designed to harmonize the BESS installation with the surrounding area, but shall not interfere with ventilation or exhaust ports.
9. **Utility Connections.** Utility connections and/or connection transmission lines shall not require a separate land use approval, but connection/transmission lines may be either determined and approved at the time of a BESS special land use approval process, or, if not finalized at the time of such approval, such lines may be approved by way of site plan approval, so long as such lines connect to an approved BESS project.
10. **Maximum Ground Floor Coverage:** For purposes of density and/or Maximum Ground Floor Coverage, Outdoor Installations shall be exempt from such calculation, although any Dedicated-Use Building shall be included in such calculation.

H. Ownership Changes.

If the owner of the battery energy storage system changes or the owner of the property changes, the special use permit shall remain in effect, provided that the successor owner or operator assumes in writing all of the obligations of the special use permit, site plan approval, and decommissioning plan. A new owner or operator of the battery energy storage system shall notify the Zoning Inspector of such change in ownership or operator within 30 days of the ownership change. A new owner or operator must provide such notification to the Zoning Inspector in writing. The special use permit and all other local approvals for the battery energy storage system may be determined by the Township Board at a public meeting to be void if a new owner or operator fails to provide written notification to the Zoning Inspector in the required timeframe, unless the new owner or operator provides a reasonable explanation for any delay. Reinstatement of a void special use permit will be subject to the same review and approval processes for new applications under this Ordinance.

I. Abandonment or Decommissioning

1. Any Tier 2 Battery Energy Storage System which has reached the end of its useful life or has been abandoned as defined within this Section shall be removed, and parcel owners shall be required to restore the site to its original condition. The owner/operator shall physically remove the installation no more than one-hundred and fifty (150) days after the date of discontinued operations. The owner/operator shall notify the Township and the Planning Commission (by certified mail) of the proposed date of discontinued operation and of plans for removal.
2. Absent notice of a proposed date of decommissioning or written notice of extenuating circumstances, the Tier 2 Battery Energy Storage System shall be considered abandoned when it ceases to operate consistently for more than one (1) year. If the owner/operator fails to comply with decommissioning upon abandonment, Saline Township may, at its discretion, enter the property and utilize the available bond and/or security for the removal of a Tier 2 Battery Energy Storage System and restoration of the site in accordance with the decommissioning plan.
3. Decommissioning shall consist of:
 - a. Physical removal of all Tier 2 Battery Energy Storage Systems, structures, equipment, security barriers, and transmission lines from the site.
 - b. Disposal of all solid and hazardous waste in accordance with local, state and federal waste disposal regulations.
 - c. Stabilization or re-vegetation of the site as necessary to minimize

erosion.

J. Performance guarantees.

A corrective action plan shall be developed for any open or continuing issues that are allowed to be continued after commissioning. A report describing the results of the system commissioning and including the results of the initial acceptance testing required in the Fire Code and Building Code shall be provided to the Zoning Inspector prior to final inspection and approval and maintained at an approved on-site location.

K. Changes to Approved Tier 2 Battery Energy Storage Systems

Minor changes to an approved Tier 2 BESS may be reviewed and approved by the Township Zoning Inspector or their designee. The Township Zoning Inspector may, at their discretion, determine that a proposed amendment constitutes a major change that requires a new special use approval by the Planning Commission. The following changes shall be considered minor:

1. Technical changes to the following application documents:
 - a. Construction documents
 - b. Fire Safety Compliance Plan
 - c. Operation and Maintenance Manual
 - d. Emergency Operations Plan
2. Modifications to, retrofits or replacements of an existing battery energy storage system that do not substantially increase the total battery energy storage system designed discharge duration, power rating, or increase the system lot coverage.

L. Enforcement

Any violation of this Section shall be subject to the same enforcement requirements, including the civil and criminal penalties, provided for in the Saline Township Code of Ordinances.

Section 5. Severability

That if any section, subsection, sentence, clause or phrase of this ordinance is, for any reason, held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this ordinance. The Township Board hereby declares that it would have passed this ordinance, and each section, subsection, clause or phrase thereof, irrespective of the fact that any one or

more sections, subsections, sentences, clauses and phrases be declared unconstitutional.

Section 6. Publication

That the Township Clerk is hereby ordered and directed to cause this ordinance to be published.

Section 7. Effective Date

That this ordinance and the rules, regulations, provisions, requirements, orders and matters established and adopted hereby shall take effect and be in full force and effect 30 days from and after the date of its final passage and adoption.

This Ordinance was offered for adoption by Robert Marion and was seconded by Tom Hammond, the vote being as follows:

YEAS: () _____

NAYS: () _____

ABSENT: () _____

Ordinance declared adopted on _____.

James Marion
Township Supervisor for the
Township of Saline

CERTIFICATE OF ADOPTION AND PUBLICATION

I, Kelly Marion, the duly elected Clerk of the Township of Saline certify that the foregoing ordinance is a true and correct copy of the ordinance enacted by the Township Board of the Township of Saline on _____ and published in the Sun Times News, a newspaper circulated in Saline Township on _____.

Kelly Marion
Township Clerk for the
Township of Saline